



Addendum #1

T25-01 - Interior Alterations at William Dunbar P.S.

Closing Date: Thursday, January 23, 2025 before 11:00 AM

Question 1:

Please provide specifications for the WB and TB.

Answer 1:

Whiteboards & Tackboards shall be supplied by ASI Visual Display Products, Delta Products, Global School Products or Martack Specialties.

Whiteboards:

Provide Anchor clips, brackets and fasteners: concealed for mounting as recommended by the manufacture.

-Facing shall be steel sheet 0.7 thickness, commercial quality to ASTM-A653/A65M, pre-cleaned and treaded to ensure maximum adhesion of an acid resistant type A (for markerboard) porcelain enamel.

-Core: Fiberboard, to CAN/ULC-S706.1, 11mm thick

-Backing: Galvanized, 0.4mm thick steel, with Z275 zinc coated to ASTM-A924/A924M

Trim Extruded Aluminum minimum 1.5 mm thick

Tackboards:

Provide Anchor clips, brackets and fasteners: concealed for mounting as recommended by the manufacture.

Facing: single layer natural cork, fine grain large granular sheet, 6mm thick, natural colour, laminated to backing. Classified as to surface burning

characteristics in accordance with CAN/ULC-S102, flame spread 55, smoke developed 55-70, fuel contributed 20.

Backing: Partial board: to CAN3-O188.1, Grade R, 6mm thick.

Trim Extruded Aluminum minimum 1.5 mm thick

Question 2:

Please provide the electrical and mechanical drawings for class rooms (Both base bid and separate price)

Answer 2:

The scope of work for the standard school classrooms both base bid and unit price is shown on drawing A105. Review drawing A105 for minor electrical and mechanical work.

Question 3:

Please provide the finish schedule for class rooms - Flooring & Painting

Answer 3:

Refer to drawing A601 & 602 for standard classrooms (both base bid and unit price) use the same listed products for new VCT flooring, painting, millwork, and ceiling finishes. New sink and faucet for standard classrooms shall be SK-1 countertop sink noted on M001.

No painted accent walls required for the standard classrooms.

End of Addendum #1